

Article

A Model For Remote Depth Estimation Of Buried Radioactive Wastes Using CdZnTe Detector.

Ikechukwu Kevin Ukaegbu ^{1,*}, Kelum A. A. Gamage ²

¹ Engineering Department, Lancaster University, Lancaster LA1 4YW, UK; i.ukaegbu@lancaster.ac.uk

² School of Engineering, University of Glasgow, Glasgow G12 8QQ, UK; Kelum.Gamage@glasgow.ac.uk

* Correspondence: i.ukaegbu@lancaster.ac.uk

Version May 16, 2018 submitted to *Sensors*

Abstract: This paper presents the results of an attenuation model for remote depth estimation of buried radioactive wastes using a Cadmium Zinc Telluride (CZT) detector. Previous research using an organic liquid scintillator detector system showed that the model is able to estimate the depth of a 329 kBq Cs-137 radioactive source buried up to 12 cm in sand with an average count rate of 100 cps. The results presented in this paper showed that the use of the CZT detector extended the maximum detectable depth of the same radioactive source to 18 cm in sand with a significantly lower average count rate of 14 cps. Furthermore, the model also successfully estimated the depth of a 9 kBq Co-60 source buried up to 3 cm in sand. This confirms that this remote depth estimation method can be used with other radionuclides and wastes with very low activity. Finally, the paper proposed a performance parameter for evaluating radiation detection systems that implement this remote depth estimation method.

Keywords: remote depth profiling; attenuation model; radiation detection; radioactive contamination; radiological characterisation; nuclear wastes; nuclear decommissioning; cadmium zinc telluride.

1. Introduction

Wastes generated during the nuclear fuel cycle can end up in the soil resulting in large scale land contamination. This is the case in the beaches of Dounreay in Northern Scotland where wide spread radioactive soil contamination has been reported [1,2]. This was caused by the so called Dounreay particles resulting from the processing of the fuels from the Material Test Reactor at the Dounreay nuclear facility. These particles consist mainly of caesium-137 (Cs-137) fuel fragments buried at depths less than 40 cm and extending over an area of about 200,000 m². Other sources of shallow subsurface radioactive contamination include: leaks from waste pipes [3,4] and radioactive fallout from nuclear tests [5]. The characterisation of these subsurface wastes has continued to be a major nuclear decommissioning challenge [6]. This is mainly because of the difficulty in estimating the depth of penetration of these contaminants without having recourse to destructive methods such as logging or core sampling [7,8]. Furthermore, reported non-intrusive depth estimation methods for such wastes are either based on empirical models [9,10] or are limited to a maximum depth of 3 cm [11,12].

Consequently, a novel remote depth estimation method for buried waste was recently developed [13]. This method is based on an approximate three-dimensional linear attenuation model that makes use of multiple radiation measurements obtained from the surface of the material in which the radioactive contaminant is buried. The results from simulation showed that the method is able to estimate the depth of radioactive point sources buried up to 40 cm in both sand and concrete. Furthermore, results from initial experiments using an organic liquid scintillator (EJ-301) from Eljen Technologies (Sweetwater, TX, USA) and a high speed multichannel analyser MFAx1.3 from

Hybrid Instruments Limited (Lancaster, Lancashire, UK) achieved a maximum detectable depth of approximately 12 cm at an average count rate of 100 cps, where the average count rate is defined as the average of the count rates at each depth when the detector is located axially with the source. These preliminary results indicate that improved results can be obtained using a radiation detector with a better gamma spectral response. This is because the gamma spectral response of the EJ-301 scintillator is limited to the Compton continuum.

Therefore, this paper presents improved results from the depth estimation method using a Cadmium Zinc Telluride (CZT) detector. The CZT is a semiconductor detector that is well known for its good spectral response at room temperature [14]. Consequently it is widely used in the characterisation of nuclear materials in fields such as nuclear safeguard and decommissioning [15,16]. The paper also reports on the effect of data acquisition time on the depth estimation performance of the method and proposes a performance parameter for evaluating systems that will implement the depth estimation method. The next section gives a detailed description of the materials and methods used in the research. The experimental results are presented and discussed in Section 3 while the conclusions and future directions are presented in Section 4.

2. Materials and Methods

2.1. The approximate three-dimensional linear attenuation model

Let $I_{(x,y,z)}$ be the radiation intensity measured at any position (x, y) on the surface of a material volume in which a radiation source is buried at depth z . The ratio of this intensity to that measured from a reference position (i.e. $(x, y) = (0, 0)$) on the same z surface is given by:

$$\log_e(J_{(x,y,z)}) \approx -\frac{\mu}{2z}(x^2 + y^2) + \log_e(K_{(x,y,0)}) \quad (1)$$

where $J_{(x,y,z)} = \frac{I_{(x,y,z)}}{I_{(0,0,z)}}$, μ = linear attenuation coefficient, and $K_{(x,y,0)} = \frac{I_{(x,y,0)}}{I_{(0,0,0)}}$. Equation 1 is the approximate linear three-dimensional linear attenuation model derived in a previous work [13]. It expresses the ratio of the intensity measured at any position on the surface of the material volume to that measured at the central position on the same surface. Furthermore, it can be deduced that the approximate depth of the source can be estimated from the gradient of model. The gradient can be obtained by fitting a linear polynomial to the graph of the model for a set of spectra acquired from multiple positions on the surface of the material volume in which the source is buried. The simulation result of this procedure for Cs-137 buried in sand at depths from 2 cm to 20 cm at 2 cm interval is shown in Figure 1. The deviation observed at increasing depth is as a result of the approximation made in the derivation of Equation 1. Details of the model derivation and a comprehensive analysis of simulation results have been reported in [13].

2.2. Experiment

The experimental setup (Figure 2) consisted of a sandbox filed with sand in which the radiation source was placed at varying distances from the front surface. The walls of the box are 0.8 cm thick and were constructed using acrylic plastic sheets. The density of the sand is 1.66 g cm^{-3} and the weight fractions of its composite elements obtained using Scanning Electron Microscopy (SEM) are shown in Table 1. The source was attached to one end of a plastic pipe whose other end protrudes behind the box and was used to vary the distance of the source from the front of the sandbox. The detector was placed inside the cylindrical tungsten collimator shown in Figure 2 so that only gamma rays within the detector's field of view are detected at each x-y position. The collimator is 1 cm thick, 25 cm tall and has an internal diameter of approximately 4 cm. Furthermore, the collimator was attached to a motorised mount for automated positioning of the detector at each measurement position on the front surface of the box.




Figure 1. Estimated depth from the simulation of Cs-137 point source buried in sand [13]. Index refers to the position of each depth value in the depth array i.e. 1 = 2 cm, 2 = 4 cm, 3 = 6 cm etc.




Figure 2. Setup for the experiment. The Cs-137 point source was placed at varying position along the z-axis using a pipe that protruded behind the box while the intensity was measured at the grided positions marked on the surface of the sandbox

Table 1. Elemental composition from SEM analysis of the sand used in the experiment.

Element	Weight fraction
C	0.1714
O	0.5163
Na	0.0013
Al	0.0151
Si	0.2755
K	0.0072
Ca	0.0006
Fe	0.0072
P	0.0003
S	0.0004
Ti	0.0005
Cu	0.0009
Mg	0.0020
Zn	0.0014
1.0000	

74 In order to acquire the data, the total scanning area was set to $28 \times 28 \text{ cm}^2$ which was divided into
 75 $4 \times 4 \text{ cm}^2$ grids. The size of the grids were chosen to be approximately equal to the internal diameter
 76 of the collimator. The radiation source was then positioned at distances (i.e. depths) varying from 2
 77 cm to 20 cm at 2 cm intervals from the front of the sandbox. At each depth, the detector was moved
 78 across the scanning area and the spectrum of the buried source was measured at each grid thereby
 79 yielding a total of 49 spectra per depth.

80 2.3. Spectrum acquisition and preprocessing

81 The detector used in the experiment was the CZT/500S detector from Ritec (Riga, Latvia). It is a
 82 quasi hemispherical CZT detector with a sensitive volume of 0.5 cm^3 and is enclosed in a cylindrical
 83 casing of diameter 2.2 cm and height 3.3 cm. Therefore it is able to fit inside the collimator used in the
 84 experiment. The output from the detector was connected to a charge sensitive low noise preamplifier
 85 (PA101C also from Ritec) and the output pulses were sampled by an oscilloscope (sampling rate = 500
 86 kS/s) controlled by a personal computer (PC). After digitisation by the oscilloscope, the pulse was
 87 then transferred to the PC via ethernet for pulse height analysis (PHA). The stages of the PHA are
 88 as shown in Figure 3. It consists of a fast and a slow processing channels whose output are used by
 89 the pile-up rejector to estimate the height of suitable pulses. The details of the PHA are discussed as
 90 follows:




Figure 3. Pulse height spectrum analysis algorithm used in the experiment where MWD is the Moving Window Deconvolution and MAF is the Moving Average Filter

91 (a) Moving Window Deconvolution:

92
 93 The MWD is an efficient filter proposed by Georgiev *et al* [17] for the retrieval of amplitude of the
 94 step pulse from the output of the preamplifier. The charge collected when a photon strikes the CZT
 95 crystal creates a fast rising step in the output of the preamplifier with an amplitude that is proportional
 96 to the amount of charge collected. However, the step decays exponentially at a rate determined the
 97 time constant of the preamplifier. This delay of the signal to return to baseline prevents the accurate
 98 measurement of the amplitude of subsequent voltage steps. However, since the output from the
 99 preamplifier is a convolution of the charge distribution function and the impulse response of the
 100 preamplifier, deconvolving this output signal will enable the reconstruction of the original charge
 101 distribution function while eliminating poles from the preamplifier transfer function [17]. The MWD
 102 performs this deconvolution in a moving time window and is given by:

$$MWD(i) = X(i) - X(i - M) + \frac{1}{\tau} \sum_{j=i-M}^{i-1} X(j) \quad (2)$$

103 where $X(i)$ is the value of the signal at the i th sample, M is the window size and τ is the preamplifier
 104 time constant in unit of sample time. It can be observed that the MWD is a differentiator followed
 105 by an integration term that compensates for the exponential decay using the time constant of the
 106 preamplifier.

107 (b) Moving Average Filter:

108
 109 The Moving Average Filter is an optimum constant weight smoothing filter suitable for reducing
 110 random noise. It was applied to the output of the MWD so as to reduce the noise level without affecting
 111 the energy resolution [18]. It is given by:

$$MAF(i) = \frac{1}{L} \sum_{j=i-L}^{i-1} MWD(j) \quad (3)$$

112 where L is the filter length. The value of L in relation to the MWD window size M determines the
 113 output pulse shape. For instance, $L < M$ results in trapezoidal shaping while $L = M$ results in
 114 triangular shaping.

115 (c) Pile-up rejection:

116
 117 Pile-up is caused by two or more events occurring within the duration of the length of the shaping
 118 filter (i.e. the window size of the MWD). This causes the events to be processed into a single pulse
 119 resulting in wrong estimation of the pulse amplitude. The need to reduce pile-ups is usually in conflict
 120 with the need to ensure complete charge collection. This is because while long shaping times increase
 121 the probability of complete charge collection, they also increase the occurrence of pile-ups especially
 122 at high count rates. Pile-up rejection was implemented in PHA by having two processing channels:
 123 a slow channel with a longer shaping time for increased probability of complete charge collection
 124 and a fast channel with a shorter shaping time for resolving closely occurring events. Therefore, any
 125 pulse from the slow channel with more than one pulse within the same duration in the fast channel is
 126 rejected as a pile-up.

127
 128 The PHA algorithm was implemented in MATLAB (Natick, MA, USA) and used to process the
 129 pulses transferred from the oscilloscope. The Cs-137 spectrum obtained after 50,000 counts using a
 130 long and short filter shaping times of $10 \mu\text{s}$ and $7 \mu\text{s}$ respectively is shown Figure 4. It can be observed
 131 that all the key features of the Cs-137 gamma spectrum can be clearly identified.




Figure 4. Cs-137 spectrum from the PHA algorithm after 50,000 counts

132 2.3.1. Photo-peak fitting

One of the problems with the spectrum produce by CZT detectors is the elongated low-energy tail of the photo-peak. This is because of incomplete charge collection caused by early carrier recombination due to low hole mobility within the CZT crystal [19]. Consequently, the obtained spectrum photo-peaks are often asymmetric and cannot be adequately described by conventional Gaussian functions. Therefore, Montreau et al [19] proposed a more robust peak fitting function given as:

$$F(i) = G(i) + S(i) + D(i) + B(i) \quad (4)$$

where i is the channel number, G is a Gaussian function given by:

$$G(i) = H_g \exp[-(i - i_0)^2 / 2\sigma^2] \quad (5)$$

where H_g is the amplitude of the Gaussian function, i_0 is the centroid, σ is the standard deviation. $S(i)$ is a step function given by:

$$S(i) = H_s H_g \operatorname{erfc}[(i - i_0) / \sqrt{2}\sigma] \quad (6)$$

where H_s is the height of the step. $D(i)$ is an exponential tailing function described as:

$$D(i) = H_t H_g \exp[(i - i_0) / T_s \sigma] \times \operatorname{erfc}[(i - i_0) / \sqrt{2}\sigma] + 1 / (\sqrt{2} T_s) \quad (7)$$

133 where T_s is the inverse slope of the exponential tail. The last component of fitting function $B(i)$
 134 represents background radiation however, it can be neglected if background subtraction is performed
 135 before fitting the function to the photo-peak. Figure 5 shows the application of Equation 4 to the 662
 136 keV photo-peak of the acquired Cs-137 spectrum. The contribution of each component of the fitting
 137 function to the accuracy and robustness of the fit can be observed. Therefore, this photo-peak fitting
 138 function was used to analyse the spectra obtained from the experiments after background subtraction.




Figure 5. Cs-137 662 keV photopeak fitting using Equation 4

139 3. Results and Discussions

140 3.1. Results for Caesium-137

141 The two-dimensional radiation image for some selected depths between 2 cm to 20 cm for a
 142 329 kBq Cs-137 point source buried in the sandbox are shown in Figure 6. The pixel values of each
 143 image are the photon count at 662 keV of the spectrum acquired at that position on the front surface
 144 of the sandbox. In addition, the spectra were acquired using a scanning time of 25 minutes per x-y

145 position. It can be observed that the images show an increasing defocussing of the intensity from
 146 the center towards the edges as the depth increases. This shows that the distribution of the intensity
 147 across the image pixels contains information about the depth of the source. Furthermore, it can be
 148 observed that at depth of 20 cm, the pixel intensities become randomly distributed. This is because
 149 of significant attenuation which causes some pixels to have zero values. These zero-valued pixels
 150 represents positions where the photo-peak fitting function failed due to its inability to detect a peak.
 151 This distribution of the intensities across the image in addition to the decrease in the photon count due
 152 to attenuation are the two pieces of information exploited by this method to estimate the depth of the
 153 buried radioactive source.




Figure 6. Normalised radiation images of Cs-137 buried in sand for selected depths.

154 The next step in the depth estimation process is the evaluation of the model (i.e. Equation 1) using
 155 the radiation images. The graphs of the model for the same selection of depths whose images are
 156 shown in Figure 6 are shown in Figure 7. It can be observed that the graphs have negative gradients as
 157 predicted by the model. Furthermore, it can also be observed in the graphs in Figure 7 that the gradient
 158 of the fitted polynomial tends to zero as the depth increases. This shows that the model aptly preserves
 159 the attenuation behaviour of gamma rays in materials. In addition, it also implies that the gradient
 160 of the data points contain information about the depth of the source. And that the quantity of depth
 161 information in the gradient decreases as the gradient value tends to zero where a zero gradient value
 162 means no depth information. However, it must be noted that zero represents an absolute limit because
 163 the reliability of the depth estimates will become significantly reduced even before the gradient value
 164 becomes zero.

165 The depths of the source estimated from the gradient of the model are shown in Figure 8a. The
 166 linear attenuation coefficient μ at 662 keV for sand was calculated using the weight fractions in Table 1
 167 and the mass attenuation coefficients published by the National Institute of Standards and Technology
 168 (Gaithersburg, MD, USA) [20]. It can be observed that the estimated depth well approximates the real
 169 depth up to 6 cm after which the expected deviation from the real depth begins. As explained in [13],
 170 this deviation is as a result of using only the first two terms of the binomial expansion in the derivation
 171 of the model. This deviation continues up to 16 cm after which a slight upward jump can be observed
 172 at 18 cm. This slight jump at 18 cm indicates the depth at which the effects of attenuation begins to
 173 introduce errors in the estimate. This slight jump is followed by a complete divergence of the estimated




Figure 7. Graphs of the model for Cs-137 buried in sand for selected depths. (x, y) is the position of the detector on the surface of the sandbox while J is the ratio of the intensity measured at each (x, y) to that measured at the center of the sandbox surface

174 depth from the real depth at 20 cm due to large errors in the estimate caused by significant attenuation
 175 of the gamma rays. This complete divergence in the estimated depth at 20 cm is corroborated by the
 176 complete defocussing of the radiation image at 20 cm (Figure 6) and the almost zero gradient of the
 177 fitted polynomial in the model graph also at 20 cm (Figure 7).




Figure 8. (a) Real and estimated depths for Cs-137 buried in sand. Index is the position of each depth value in the depth array i.e. 1 = 2 cm, 2 = 4 cm, 3 = 6 cm etc.; (b) Linear fit of real and estimated depth for Cs-137 buried in sand.

178 Figure 8b shows that there is a linear relationship from which the real depth can be predicted
 179 from the estimated depth up to 18 cm with an adjusted R-squared value of 0.98. The estimate at 20 cm
 180 was not included in the linear fit. In addition, a weighted linear regression was used to limit the effect
 181 of the slight error in the estimate at 18 cm on the regression parameters. The average corrected count
 182 rate obtained for this experiment was 14 cps due to the slow communication link between the PC and

183 the oscilloscope. However, the result is a significant improvement to the result previously obtained
 184 using the EJ-301 scintillator [13] which achieved a maximum detectable depth of 12 cm with a scanning
 185 time of 10 minutes per x-y position despite operating at significantly higher average count rate of 100
 186 cps. This means that using this method with a CZT detector and a conventional multichannel analyser
 187 rather than the improvised setup used in this experiment can achieve a maximum detectable depth
 188 greater than 18 cm in less than 10 minutes scanning time. This improvement is mainly due to the
 189 good gamma energy resolution of the CZT detector which enabled the use of photon counts from the
 190 photo-peak in the depth estimation. Conversely, the experiment with the EJ-301 used photon counts
 191 from the Compton peak because the EJ-301 could only produce the Compton continuum of the gamma
 192 spectrum. Finally, this result confirms that while photon counts from any part of the spectrum can be
 193 used with the model, photon counts from the photo-peak will yield the best results.

194 3.1.1. Effect of scanning time

195 The estimated depths for different scanning times per x-y position namely: 15, 20 and 25 minutes,
 196 are shown in Figure 9a. A gradual but progressive improvement in the estimated depth at 16 cm and 18
 197 cm can be observed as the scanning time increases (see points indicated on the graph). This progressive
 198 improvement in the estimated depth results in the progressive restoration of the graph to the expected
 199 deviation pattern as the scanning time increases. The gradual rate at which the estimates improves
 200 with time indicates that this relationship is exponential. This is confirmed by Figure 9b which is the
 201 graph of the absolute error in the estimate as a function of the count rate for the 20 minutes scanning
 202 time experiment. The decay rate of this graph indicates how quickly the error in the estimated depth
 203 decreases as the count rate increases and it is independent of the scanning time. Furthermore, dividing
 204 this decay rate by the density of sand will make it also independent of the material in which the source
 205 is buried. This will result in a value that is dependent only on the efficiency of the instrumentation (i.e.
 206 detector and related electronics) used. Therefore, this value can be used as a parameter for evaluating
 207 and selecting appropriate instrumentation for field application of this remote depth estimation method.




Figure 9. (a) Estimated depths for three different scanning times. Index is the position of each depth value in the depth array i.e. 1 = 2 cm, 2 = 4 cm, 3 = 6 cm etc.; (b) Exponential decrease of the absolute error in the estimated depth with increasing count rate

208 The gradients and intercepts for the linear fit between the real and estimated depths for the three
 209 scanning times and those from simulation (reported in [13]) are shown in Table 2. The depths column
 210 in the table refers to the range of depths over which the parameters were estimated. It can be observed
 211 that the values of these parameters are relatively constant and do not vary significantly with depth.
 212 This means that the values of these parameters can be assumed to be constant for any given material
 213 and gamma energy. Therefore, this method can be used to investigate radioactive wastes buried at any

214 depth in a given material without the need of calibration. This is not the case with the empirical model
 215 proposed in [9,10] where new model parameters must be obtained in order to estimate depths outside
 216 the range of depths used to develop the model.

Table 2. Parameters for the linear fit between the real and estimated depth from experiments and simulation.

	Depths (cm)	Gradient	Intercept
Experiment			
15 minutes	2 - 14	1.4 ± 0.1	-1.6 ± 0.9
20 minutes	2 - 16	1.4 ± 0.1	-1.5 ± 1.2
25 minutes	2 - 18	1.5 ± 0.2	-2.2 ± 1.6
Simulation [13]	2 - 40	1.6 ± 0.1	-2.0 ± 0.6

217 3.2. Results for Cobalt-60

218 The experiment was also carried out using a 9 kBq Co-60 point source. Due to the low activity of
 219 the source, the scanning area was reduced to $20 \times 20 \text{ cm}^2$ while the scanning time was increased to 40
 220 minutes per x-y position. The results for both the 1.77 MeV and 1.33 MeV photo-peaks of the Co-60
 221 gamma spectrum for depths from 1 cm to 4 cm at 1 cm interval are shown in Figures 10a and b. The
 222 similarity in the estimated depths from both peaks can be observed up to 3 cm after which both graphs
 223 differ dramatically. This is not expected because gamma rays from both energy peaks have similar
 224 mass attenuation coefficient i.e. 0.059 for 1.17 MeV gamma rays and 0.0552 for 1.33 MeV gamma rays.
 225 In addition, gamma rays from both energy peaks have the same probability of being emitted from
 226 Co-60 nucleus. Due to these reasons, estimates after 3 cm were considered to be erroneous and were
 227 thus excluded from the linear fit between the real and estimated depths shown in Figure 10b. This
 228 is a significant improvement over the technique reported in [12] which achieved a similar maximum
 229 depth limit for a 40 kBq Co-60 source buried in sand. Finally, these results confirm that this method
 230 can be used with other radionuclides and low level buried wastes.




Figure 10. (a) Real and estimated depths for Co-60 buried in sand. Index is the position of each depth value in the depth array i.e. 1 = 2 cm, 2 = 4 cm, 3 = 6 cm etc.; (b) Linear fit of real and estimated depth for Co-60 buried in sand.

231 4. Conclusion

232 Improvements in the depth estimation results of the approximate 3D attenuation model using
 233 a CZT detector have been presented. The results showed that the model is able to non-intrusively
 234 estimate the depth of a 329 kBq Cs-137 radioactive source buried up to 18 cm in sand with a significantly
 235 lower average count rate of 14 cps compared to previous results of 12 cm with a average count rate of

236 100 cps. This will enable the rapid non-intrusive localisation of buried radioactive wastes. Furthermore,
237 the results confirmed that depth limit depends on the data acquisition time. Therefore, increasing
238 the data acquisition time will enable the estimation of the depth of wastes buried deeper in the
239 sand. In addition, the result from the experiment using a 9 kBq Co-60 radioactive source confirmed
240 that the model can be used with any gamma radiation source and is also capable of estimating the
241 depth of buried sources with very weak activity. Also, the explicit dependence of the model on
242 the density of the material means that this method can be extended to any material e.g. concrete
243 by substituting the material's density into the model. Consequently, the method will find wide
244 application in nuclear decommissioning, land remediation, nuclear security and non-proliferation
245 activities. Finally, areas of further research include investigation of the method's performance using
246 non-point sources and multiple hot spots within the scanning area. These will further improve the
247 robustness of this non-intrusive depth estimation method.

248 **Acknowledgments:** This work was supported by the Engineering and Physical Sciences Research Council
249 (EP/N509231/1) and Nuclear Decommissioning Authority, UK. The authors will also thank Dr. Michael Aspinall
250 for his suggestions during the preparation of the manuscript

251 **Author Contributions:** Ikechukwu Kevin Ukaegbu carried out the research while both authors contributed in
252 preparing the manuscript.

253 **Conflicts of Interest:** The authors declare no conflict of interest.

254 References

- 255 1. Charles, M.; Harrison, J.; Darley, P.; Fell, T. Health implications of Dounreay fuel fragments: Estimates of
256 doses and risks. *Proc. Seventh Int. Symp. Soc. Radiol. Prot.; Society for Radiological Protection: Cardiff,*
257 *UK, 2005; pp. 23–29.*
- 258 2. Wilkins, B.T.; Harrison, J.D.; Smith, K.R.; Phipps, A.W.; Bedwell, P.; Etherington, G.; Youngman, M.; Fell,
259 T.P.; Charles, M.W.; Darley, P.J. Health implications of fragments of irradiated fuel at the beach at Sandside
260 Bay Module 6 : Overall results. Technical report, Health Protection Agency, Oxfordshire, UK, 2006.
- 261 3. Miller, B.; Foster, A.; Nuvia, M.D.; Hill, M.; Foster, A. Pipeline Characterisation and Decommissioning
262 within the Nuclear Industry : Technology Review and Site Experience. Technical Report 2, Nuclear
263 Decommissioning Authority, Cumbria, UK, 2016.
- 264 4. Miller, B.; Foster, A.; Burgess, P.; Metrology, R.; Hill, M.; Foster, A. Pipeline Characterisation and
265 Decommissioning within the Nuclear Industry : Good Practice Guide. Technical Report 2, Nuclear
266 Decommissioning Authority, Cumbria, UK, 2016.
- 267 5. Lal, R.; Fifield, L.; Tims, S.; Wasson, R. 239 Pu fallout across continental Australia: Implications on 239 Pu
268 use as a soil tracer. *J. Environ. Radioact.* **2017**, *178–179*, 394–403.
- 269 6. Adams, J.C.; Mellor, M.; Joyce, M.J. Depth determination of buried caesium-137 and cobalt-60 sources
270 using scatter peak data. *IEEE Trans. Nucl. Sci.* **2010**, *57*, 2752–2757.
- 271 7. Popp, A.; Ardouin, C.; Alexander, M.; Blackley, R.; Murray, A. Improvement of a high risk category source
272 buried in the grounds of a hospital in Cambodia. 13th Int. Congr. Int. Radiat. Prot. Assoc.; , 2012; pp. 1–10.
- 273 8. Maeda, K.; Sasaki, S.; Kumai, M.; Sato, I.; Suto, M.; Ohsaka, M.; Goto, T.; Sakai, H.; Chigira, T.; Murata, H.
274 Distribution of radioactive nuclides of boring core samples extracted from concrete structures of reactor
275 buildings in the Fukushima Daiichi Nuclear Power Plant. *J. Nucl. Sci. Technol.* **2014**, *51*, 1006–1023.
- 276 9. Adams, J.C.; Joyce, M.J.; Mellor, M. The advancement of a technique using principal component analysis for
277 the non-intrusive depth profiling of radioactive contamination. *Nucl. Sci. IEEE Trans.* **2012**, *59*, 1448–1452.
- 278 10. Adams, J.C.; Joyce, M.J.; Mellor, M. Depth profiling 137Cs and 60Co non-intrusively for a suite of industrial
279 shielding materials and at depths beyond 50mm. *Appl. Radiat. Isot.* **2012**, *70*, 1150–1153.
- 280 11. Shippen, A.; Joyce, M.J. Profiling the depth of caesium-137 contamination in concrete via a relative linear
281 attenuation model. *Appl. Radiat. Isot.* **2010**, *68*, 631–634.
- 282 12. Shippen, B.A.; Joyce, M.J. Extension of the linear depth attenuation method for the radioactivity depth
283 analysis tool (RADPAT). *IEEE Trans. Nucl. Sci.* **2011**, *58*, 1145–1150.
- 284 13. Ukaegbu, I.; Gamage, K. A Novel Method for Remote Depth Estimation of Buried Radioactive
285 Contamination. *Sensors* **2018**, *18*, 1–13.

- 286 14. del Sordo, S.; Abbene, L.; Caroli, E.; Mancini, A.M.; Zappettini, A.; Ubertini, P. Progress in the development
287 of CdTe and CdZnTe semiconductor radiation detectors for astrophysical and medical applications. *Sensors*
288 **2009**, *9*, 3491–3526, [NIHMS150003].
- 289 15. Wahl, C.G.; Kaye, W.R.; Wang, W.; Zhang, F.; Jaworski, J.M.; King, A.; Boucher, Y.A.; He, Z. The Polaris-H
290 imaging spectrometer. *Nucl. Instruments Methods Phys. Res. Sect. A Accel. Spectrometers, Detect. Assoc.*
291 *Equip.* **2015**, *784*, 377–381.
- 292 16. Goodman, D.; Streicher, M.; Zhu, Y.; Brown, S.; He, Z. 1-D Fast Neutron Source Localization Using Digital
293 Pixelated 3-D Position-Sensitive CdZnTe Detectors. *IEEE Trans. Nucl. Sci.* **2017**, *64*, 2531–2535.
- 294 17. Georgiev, a.; Gast, W. Digital pulse processing in high-resolution, high-throughput, gamma-ray
295 spectroscopy. *IEEE Trans. Nucl. Sci.* **1993**, *40*, 770–779.
- 296 18. Kavatsyuk, M.; Bremer, D.; Dormenev, V.; Drexler, P.; Eissner, T.; Erni, W.; Guliyev, E.; Hennino, T.; Krusche,
297 B.; Lewandowski, B.; Löhner, H.; Moritz, M.; Novotny, R.W.; Peters, K.; Pouthas, J.; Rosier, P.; Steinacher,
298 M.; Tambave, G.; Wilms, A. Performance of the prototype of the Electromagnetic Calorimeter for PANDA.
299 *Nucl. Instruments Methods Phys. Res. Sect. A Accel. Spectrometers, Detect. Assoc. Equip.* **2011**, *648*, 77–91.
- 300 19. Mortreau, P.; Berndt, R. Characterization of cadmium zinc telluride detector spectra - application to the
301 analysis of spent fuel spectra. *Nucl. Instruments Methods Phys. Res. Sect. A Accel. Spectrometers, Detect.*
302 *Assoc. Equip.* **2001**, *458*, 183–188.
- 303 20. National Institute of Standards and Technology. X-Ray Mass Attenuation Coefficients, 2004.

304 © 2018 by the authors. Submitted to *Sensors* for possible open access publication under the terms and conditions
305 of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).